# CYLINDER AG-INDTC-68-ABC / AG-INDLC-72-xBC

Pre-engineered fixed dry chemical extinguishing system for piping networks / 68 to 72 kg

Attached pressure / Total flooding and local application

Data sheet 13210 Rev.00

## Product description


The AG-INDTC-68-ABC and AG-INDLC-72-xBC dry chemical cylinders with attached pressure are designed for pre-engineered fixed extinguishing systems, which operate with a predefined piping network and a fixed quantity of agent — in this case, between 68 and 72 kg of extinguishing agent.

Dry chemical systems are suitable for the protection of Class A hazards (combustible solid materials), Class B hazards (flammable liquids and gases), and Class C hazards (energized electrical equipment).


The system consists of a cylinder filled with dry chemical powder connected to a piping network that distributes the agent to either total flooding or local application nozzles. The dry chemical cylinder is pressurized by an attached bottle that contains the expellant agent ($N_2$), typically at 150 bar with a pressure regulator RGS-MAM-RD11 valve. Activation can be performed through manual, electrical, thermal, mechanical, and thermo-mechanical methods. Optionally, it can include a mechanical detection system. Once activated, the dry chemical cylinder is pressurized, and when the specified discharge pressure (25 bar) is reached, the chemical agent is released and distributed over the protected area through the nozzles. The discharge of the dry chemical cylinder can operate with either a rupture disc (SIDR40) or a dry chemical control valve (SVDNxx40SH).

## System components

**System with SIDR40 rupture disc**




**System with SVDNxx40SH dry chemical control valve**




## Applications

Pre-engineered dry chemical cylinders are designed for a wide range of industrial applications, including paint booths and preparation areas, coating and finishing operations, machinery and equipment areas, boiler rooms, furnaces, and electrical and mechanical rooms, as well as facilities for the storage of flammable liquids, hazardous materials, and bulk products, spill containment dikes, and quench and dip tanks.

## Technical data

| DRY CHEMICAL CYLINDER WITH ATTACHED PRESSURE | | | | |
|---|---|---|---|---|
| **Model type** | **Dry chemical filling lbs (kg)** | **Risk type** | **Dry chemical type** | **Number of nozzles** |
| INDTC-68-ABC | 149.9 (68) | Total Flooding | ABC | 8 |
| INDLC-72-ABC | 158.7 (72) | Local Application | ABC | 12 |
| INDLC-72-BC | 158.7 (72) | Local Application | BC | 12 |


**NOTE:** Class D and potassium bicarbonate Class BC dry chemical systems are also available. Contact AG Fire.



C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08 | www.agfiresprinkler.com

| Nº | Description | Type | Qty |
|---|---|---|---|
| 1 | Cylinder | INDTC-68-ABC, INDLC-72-ABC, INDLC-72-BC | 1 |
| 2 | Fixing Brackets | POHCxxx | 1 |
| 3 | Elbow adapter | 541CO21, 541CO20 | 1 |
| 4 | $N_2$ expellant cylinder | 101M40UFxx,101M67UFxx | 1 |
| 5 | Impulsion hose | DH15, DH15CO, DH15I, DH16, DH16I | 1 |
| 6 | Expellant cylinder valve | RGS-MAM-RD11 | 1 |
| 7 | $N_2$ Pilot cartridge | 100M008UFxx, 100M018UFxx | 1 |
| 8 | Pressure Gauge | 5140-W40, 5140-W60, 5140-W250, UF40I-P24, UF40I-P150, UF40I-P200 | 2 |
| | Pressure Gauge with electrical contacts (optional) | 5140-E40SP13, 5140-E60SP22, 5140-E250SP144, 5140-E250SP180, UF40I-E24, UF40I-E150, UF40I-E200 | |
| 9 | Cartridge valve | RGS-MAM-03 | 1 |
| 10 | Mechanical detection and actuator (optional) | TK-SIMPLEX-B, TK-COMPLEX-B, TK-SIMPLEX-C, TK-COMPLEX-C, KCTM-R, KCTM-C | 1 |
| 11 | Electrical actuator | 227SOLR, 227SOLCR, 227SOLCR125 | |
| 12 | Manual actuator | 227DMR, 227DMS, 227CMCC, 227CMC, 227CN, 227CNM, KCTM-R, KCTM-C | |
| 13 | Pulley elbow | TK-CPx | - |
| 14 | Remote manual pull station | TK-DMS, TK-DMS2 | - |
| 15 | Nozzle | AG-TF-1, AG-O-2, AG-TK-1 | 8 or 12 |
| 16 | Tank valve | DCHD50, DCHDN50 | 1 |
| 17 | Bursting disc | SIDR40 | 1 |
| 18 | Pressure switch (optional) | POPRENA50, POPRENC50, APRESA50, APRESC50 | 1 |
| 19 | ATEX pressure switch (optional) | Popreco-AD413 | |
| 20 | Pressure switch (opcional) | POINPRExx | 1 |
| 21 | ATEX pressure switch (opcional) | POINPREAD-ATEXxx | |
| 22 | Dry chemical control valve | SVDNxx40SH | 1 |
| 23 | Activation flexible hose ¼” | FH-6PO, FH-7PO, DH10, DH10I, DH11, DH11I | 1 |
| 24 | Pilot valve | FTSV-6 | 1 |
| 25 | Check valve | VALAN-12P | 1 |

## Dimensions






C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08 | www.agfiresprinkler.com

| DIMENSIONS OF $N_2$ EXPELLANT PILOT CYLINDER | | |
|---|---|---|
| **Cylinder capacity** | **101M40UFxx** | **101M67UFxx** |
| | 1.41 $ft^3$ (40L) | 2.38 $ft^3$ (67,5L) |
| **$N_2$ Pressure** | 150 bar | 166 bar |
| **(F) Inch (mm)** | 48.8 ±0.39 (1240 ±10) | 57.9 ±0.39 (1470 ±10) |
| **(ØG) Inch (mm)** | Ø9.0 ±0.08 (Ø229 ±2) | Ø10.5 ±0.08 (Ø267 ±2) |


## SIDR40 bursting disc

This bursting disc allows the dry chemical cylinder to be discharged once a pressure of 25 bar is reached. The disc is installed at the outlet of the cylinder, between the cylinder valve and its cap. When the required pressure is reached, the disc bursts and the extinguishing agent flows into the discharge pipe, from where it is distributed to the nozzles.




## SVDNxx40SH dry chemical valve


The SVDNxx40SH control valve releases the dry chemical from the cylinder once a pressure of 25 bar is reached. The actuator of the control valve is connected to the dry chemical cylinder via the activation hose. When the required pressure is reached, the actuator opens the valve, allowing the extinguishing agent to flow into the discharge pipe and be distributed to the nozzles.




## Pressure switch (optional)

The pressure switch is a monitoring device that sends an electrical signal to the fire control panel when the pressure in the cylinder drops.

It is factory-supplied preassembled on the cylinder valve, in the corresponding port. Inside the device, there is a dry contact that opens or closes an electrical circuit depending on the pressure condition. There are two variants available: NC (normally closed, opens under pressure) and NO (normally open, closes under pressure).




POPRENxxx APRESxxx

## Electrical activation (optional)


**227SOLR resettable electric actuator head (24VDC)**

The purpose of this actuator is to electromagnetically actuate the container valves where it is installed. It is activated when the coil is energized, causing the solenoid to operate and actuate the valve.

This actuator is resettable — the pin returns to the standby position by threading a reset screw into its revolving nut.

The mechanism used to connect it to the container valve includes a revolving nut, allowing it to be properly oriented in the desired direction.

If installation conditions require special protection, please contact AG-IND to inquire about the availability of appropriately rated enclosures.






C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08 | www.agfiresprinkler.com

## Manual activation

### 227DMS manual actuator head

This actuator allows manual activation of the container valves where it is installed. Once the safety pin is removed from the actuator, the push button can be pressed to activate the container valve and initiate discharge.

The 227DMS is connected ONLY to the upper actuation port of the 227SOLR, 227SOLCR and 227SOLCR125 electric actuators, by means of a revolving nut that allows its proper orientation.





1- Resettable electrical actuator head 227SOLR / 227SOLCR / 227SOLCR125
2- Manual actuator head 227DMS

### 227DMR manual actuator head

The function of this actuator is to manually activate the container valves where it is installed. Once the safety ring is removed from the actuator, the manual lever can be turned in the opposite direction.

The 227DMR manual actuator can be installed on the upper actuation port of the RGS-MAM-03 valve, or mounted on top of the electric actuator installed on that valve, using a revolving nut that allows proper orientation.





1- Manual actuator head 227DMR
2- RGS-MAM-03 valve

### 227CMC manual cable-operated actuator head and 227CMCC with protective box

It is used to remotely actuate the extinguishing system. This cable-operated manual actuator head can be installed on top of the electric actuator mounted on the RGS-MAM-03 valve, and is connected by cable inside a conduit (protective pipe) to the remote manual pull station.

The lever end includes a hole to tie the cable. The only difference between the 227CMC and 227CMCC models is that the latter (227CMCC) is housed inside a protective enclosure.


The cable is installed inside a steel pipe, using pulley elbows (TK-CPx) that allow for the directional changes required by obstacles and the elevation variations needed to reach the 227CMC or 227CMCC manual cable-operated actuator head.




### TK-CPx pulley elbow

The pulley elbow is installed as part of the manual cable-operated actuator head and provides a change of direction with minimal force loss due to friction. Its function is to drive the stainless steel cable to avoid obstacles through the necessary directional changes to connect the remote manual pull station without tension (TK-DMS) with the 227CMC or 227CMCC manual cable actuator.

In addition, it connects the detection kits with the mechanical control unit and with all components that operate using detection cable. It contains a small internal bearing to guide the cable and completely eliminate friction.




ⓘ **This document provides a simplified overview of the most common system components. A wide range of detection, activation and control devices is available to meet the specific requirements of each installation.**

**For further information, please contact AG FIRE SPRINKLER.**


C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08 | www.agfiresprinkler.com


## Nozzles

Its function is to discharge the extinguishing agent into the protected area as homogeneously as possible to achieve effective suppression.

With the AG-INDTC-68-ABC dry chemical cylinders, up to 8 nozzles can be installed, while the AG-INDLC-72-xBC can be installed with up to 12 nozzles, which model depends on the application:

**AG-TF-1 total flooding nozzle**

This nozzle is intended for total flooding application of dry chemical and is threaded onto the discharge piping in a vertical position.



**AG-O-2 local application nozzle**

Designed for local application fire protection systems, it is threaded onto the discharge pipe in a vertical position.



**AG-TK-1 local application nozzle**

Developed for the protection of flammable liquid storage tanks or to cover by immersion areas prone to flammable liquid spills. It is installed next to the tank and discharges at a 90º angle to the piping, creating a flat semicircular chemical blanket over the surface of the flammable liquid.



**WARNING**: This type of system is manufactured and approved for use in fixed dry chemical extinguishing installations. These products are not designed for any other use or purpose. If the product user has any questions regarding the application or use of the product, please contact +34 947 28 11 08. Any unauthorized use or application and/or any other unauthorized modification of the product or its function may cause serious accidents and/or personal injury. AG Fire is not responsible for any unauthorized use of the application.

**IMPORTANT**: This document is not binding. AG Fire Sprinkler reserves the right to make any changes to the document without prior notice.



C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08 | www.agfiresprinkler.com