# HOSE FIRE CONNECTION VALVES

## Model A53


## Hose valve straight pattern with hose coupling, cap and chain 2 ½” DN65



## PRODUCT DESCRIPTION

| | |
|---|---|
| **Model** | A53 |
| **Dimensions** | 2 ½” DN65 x 2 ½” DN65 |
| **End connections** | Inlet: Threaded female 2 ½” NPT<br>Outlet: Threaded male 2 ½” NH (NST), with cap and chain |
| **Working pressure** | 300 psi (21 bar) |
| **Material** | Brass |
| **Finish** | Natural |

## DIMENSIONS




| VALVE SIZE | | DIMENSIONS inches (mm) | | | | |
|---|---|---|---|---|---|---|
| **INLET** | **OUTLET** | **A** | **B** | **C** | **D** | **E** |
| 2 ½” DN65 | 2 ½” DN65 | 5 - 1/8” (130,17) | 9 - 13/16” (249,24) | 2 - 1/4” (57,15) | 2 - 1/16” (52,39) | 4 - 11/32” (110,33) |



C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

## ORDERING INFORMATION

| CONNECTIONS | CODE |
|---|---|
| 2 ½" DN65 x 2 ½" DN65 | A53065X065 |

Specify:

| | |
|---|---|
| Model | |
| Quantity | |
| Size | |

## AG FIRE SPRINKLER

AG Fire Sprinkler offers a wide selection of components. Then a list of products is presented by AG Fire Sprinkler, we can offer all these components, made with precision to protect people, anywhere, anytime.

- Sprinklers
  - Standard Coverage
  - Extended Coverage
  - Storage
  - Dry
  - Accessories
- System Valves
  - Wet
  - Dry
  - Preaction Equipment
  - Accessories
- Spray System Open Nozzles
  - High Velocity Nozzles
  - Medium Velocity Nozzles
  - Window Nozzles
  - Hydroshield Nozzles
  - Mushroom Type Nozzles
- Foam equipment
  - Tanks
  - Proportioners
  - Foam Discharge Equipment
  - Foam Concentrates
- Deluge equipment for Water Spray and Foam
  - Clapper Deluge Valves
  - Diaphragm Deluge Valves
- Monitors
  - Manual Monitors
  - Remote Monitors
  - Monitor Nozzles
  - Towers and Trolleys
- Valves
  - Butterfly Valves
  - Gate Valves
  - Check Valves
  - Pressure Control Valves
  - Test and Drain
  - Hose, Hydrant and Fire Connection Valves
  - Fire Department Connections

The equipment presented in this bulletin is to be installed in accordance with the latest published Standard of the National Fire Protection Association, Factory Mutual Research Corporation, or other similar organizations and also with the provisions of governmental codes or ordinances whenever applicable.
This documentation is not contractual. AG Fire Sprinkler reserves the right to any kind of change without notice.



*C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08*