
GA SERIES / MODEL GA1711

Dry Sprinkler
Quick Response Sprinkler
Pendent and Recessed Pendent



Pendent | Recessed Pendent

PRODUCT DESCRIPTION

Dry pendent sprinkler Model GA1711 described in this data sheet have been designed to be used in preaction systems and areas exposed to freezing temperatures, such as cold stores and other non climate-controlled areas.

Thermosensitive glass bulb 3 mm is used. The bulb contains a special liquid hermetically sealed in a glass capsule.

TECHNICAL DATA

Nominal "K" Factor	5,6 (80 metric)
Thread Size	1" NPT (ANSI B2.1)
Temperatures	135ºF (57ºC) 155ºF (68ºC) 175ºF (79ºC) 200ºF (93ºC) 286ºF (141ºC)
Maximum Working Pressure	175 psi (12 bar)
Factory Test Pressure	500 psi (34 bar)
"A" Dimension	Minimum according drawings and maximum 48" (1219 mm)
Materials	Frame: Brass Deflector: Brass Screw: Brass Bulb Seat: Brass Sealing Spring: Nickel Alloy Bulb: Glass, 3 mm size Cup for Concealed Sprinklers: Steel Outer tube: Galvanized steel Inner tube: Stainless steel
Reference	Pendent: **GA1711**
Finishes(1)	Bronze Chrome White

(1) Other finishes available under request.

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

OPERATION

At normal temperatures, the glass bulb contains the fluid in both the liquid phase and the vapor phase. The vapor phase can be seen as a small bubble. As heat is applied, the liquid expands forcing the bubble smaller and smaller as the liquid pressure increases. Continued heating forces the liquid to push out against the bulb, causing to shatter, opening the waterway and allowing the deflector to distribute the discharging water.

INSTALLATION

Model GA1711 dry sprinklers must be installed only in standard (ANSI B 16.3 class 150 and ANSI B 16.4 class 125) pipe tees in the pendent position, even at branch line ends. They should not be installed into elbows or pipe couplings located on drop nipples to the sprinklers. For these and other fittings including CPVC, the dry sprinkler should be installed into a fitting to allow protrusion into the fitting in accordance with the diagrams. The “A” dimension of the dry sprinkler, which extends into a freezing zone from wet pipe systems, should be selected to provide, as a minimum, the specified lengths in the “Dimensions” section.

They must also be installed with the Model **AC** Sprinkler Wrench specifically designed by AG Fire Sprinkler for use with these sprinklers.

A leak tight 1" NPT (R1) sprinkler joint can be obtained with a torque of 8-18ft-lbs (10,8-24,4 N-m). Do not tighten sprinklers over maximum recommended torque. It may cause leakage or impairment of these sprinklers.


The glass bulb sprinklers are supplied with a protection for the bulb, to prevent breakage during assembly, it will be orange. Remove this guard after installation and make sure everything is correct. AG wrenches are designed to install sprinklers with the protection still in place.

TEMPERATURE RATINGS


Classification	Sprinkler Temperature		Maximum Ceiling Temp.		Bulb Color
	ºF	ºC	ºF	ºC	
Ordinary	135	57	100	38	Orange
Ordinary	155	68	100	38	Red
Intermediate	175	79	150	66	Yellow
Intermediate	200	93	150	66	Green
High	286	141	225	107	Blue

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

DIMENSIONS



DRY PENDENT SPRINKLER



DRY RECESSED SPRINKLER

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

ORDERING INFORMATION

P/N	GAXXXX Y Z LV

DESCRIPTION	CODE
Pendent	GA1711

Y			
	1	57ºC	135ºF
	2	68ºC	155ºF
	4	79ºC	175ºF
	5	93ºC	200ºF
	7	141ºC	286ºF

Z		
	1	BRASS
	2	CHROMED
	3	WHITE RAL9003

LV				
	02	2” – 5 ¾”	**27**	27” – 29 ¾”
	06	6” – 7 ¾”	**30**	30” – 32 ¾”
	08	8” – 11 ¾”	**33**	33” – 35 ¾”
	12	12” – 14 ¾”	**36**	36” – 38 ¾”
	15	15” – 17 ¾”	**39**	39” – 41 ¾”
	18	18” – 20 ¾”	**42**	42” – 44 ¾”
	21	21” – 23 ¾”	**45**	45” – 48”
	24	24” – 26 ¾”		

Specify:

Quantity	
Model Number	
Type	
Orifice	
Type deflector	
Temperature	
Finishes	
Escutcheon finish	

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

AG FIRE SPRINKLER

AG Fire Sprinkler offers a wide selection of components. Then a list of products is presented by AG Fire Sprinkler, we can offer all these components, made with precision to protect people, anywhere, anytime.

- **Sprinklers**
  - Standard Coverage
  - Extended Coverage
  - Storage
  - Dry
  - Accessories





- **System Valves**
  - Wet
  - Dry
  - Preaction Equipment
  - Accessories




- **Spray System Open Nozzles**
  - High Velocity Nozzles
  - Medium Velocity Nozzles
  - Window Nozzles
  - Hydroshield Nozzles
  - Mushroom Type Nozzles





- **Foam equipment**
  - Tanks
  - Proportioners
  - Foam Discharge Equipment
  - Foam Concentrates




- **Deluge equipment for Water Spray and Foam**
  - Clapper Deluge Valves
  - Diaphragm Deluge Valves



- **Monitors**
  - Manual Monitors
  - Remote Monitors
  - Monitor Nozzles
  - Towers and Trolleys




- **Valves**
  - Butterfly Valves
  - Gate Valves
  - Check Valves
  - Pressure Control Valves
  - Test and Drain
  - Hose, Hydrant and Fire Connection Valves
  - Fire Department Connections




The equipment presented in this bulletin is to be installed in accordance with the latest published Standard of the National Fire Protection Association, Factory Mutual Research Corporation, or other similar organizations and also with the provisions of governmental codes or ordinances whenever applicable.
This documentation is not contractual. AG Fire Sprinkler reserves the right to any kind of change without notice.

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08