
GA SERIES / MODELS GA5683 & GA5679

Dry Sprinkler
Standard Response Sprinkler
Upright, Recessed Pendent & Pendent

c UL us LISTED EX15331



Upright | Pendent | Recessed pendant | Pendant with escutcheon | Pendant with sleeve and skirt

PRODUCT DESCRIPTION

The dry sprinkler models GA5683 & GA5679 from AG Fire Sprinkler, are intended for use in dry and preaction systems to protect areas subjected to freezing temperatures and unheated portions inside and outside buildings.

Thermosensitive glass bulb 5 mm is used. The bulb contains a special liquid hermetically sealed in a glass capsule.

TECHNICAL DATA

K Factor	5,6 (80 metric)
Thread Size	1" NPT (ANSI B2.1) / ISO 7-R1 (Optional)
Nominal Orifice	½" (15 mm)
Temperatures	135ºF (57ºC) 155ºF (68ºC) 175ºF (79ºC) 200ºF (93ºC) 286ºF (141ºC)
Maximum Working Pressure	175 psi (12 bar)
Hidrostatic test pressure	500 psi (34 bar)
"A" dimension	Minimum according to drawings and maximum 48" (1219mm) in 1/4" (6 mm) increments
Reference	Upright: **GA5683** Pendant: **GA5679**
Finishes (1)	Bronze Chrome Polyester coated

(1). Other finishes available under request.

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

OPERATION

At normal temperatures, the glass bulb contains the fluid in both the liquid phase and the vapor phase. The vapor phase can be seen as a small bubble. As heat is applied, the liquid expands forcing the bubble smaller and smaller as the liquid pressure increases. Continued heating forces the liquid to push out against the bulb, causing to shatter, opening the waterway and allowing the deflector to distribute the discharging water.

INSTALLATION

Dry sprinklers model GA5683 & GA5679 must be installed only in standard (ANSI B 16.3 class 150 and ANSI B 16.4 class 125) pipe tees in the horizontal position, even at branch line ends. They should not be installed into elbows or pipe couplings located on drop nipples to the sprinklers. For these and other fittings including CPVC, the dry sprinkler should be installed into a fitting to allow protrusion into the fitting in accordance with the diagrams. The “A” dimension of the dry sprinkler, which extends into a freezing zone from wet pipe systems, should be selected to provide, as a minimum, the specified lengths in the “Dimensions” section.

They must also be installed with the Model **AC** Sprinkler Wrench, specifically designed by AG Fire Sprinkler for use with these sprinklers.


A leak tight ½” NPT (R1/2) sprinkler joint can be obtained with a torque of 8-18ft-lbs (10.8-24.4N-m). Do not tighten sprinklers over maximum recommended torque. It may cause leakage or impairment of these sprinklers.

The sprinklers come with an orange protection, to avoid breakage during assembly. Remove this protection once installed and made sure that everything is correct. The AG Sprinkler Wrenches are designed to install sprinklers with the protection still.

TEMPERATURE RATING


Classification	Nominal Temperature		Max. Ambient Temperature		Bulb Color
	ºF	ºC	ºF	ºC	
Ordinary	135	57	100	38	Orange
Ordinary	155	68	100	38	Red
Intermediate	175	79	150	66	Yellow
Intermediate	200	93	150	66	Green
High	286	141	225	107	Blue

DIMENSIONS




DRY UPRIGHT SPRINKLER

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08




DRY PENDANT SPRINKLER




DRY PENDANT SPRINKLER WITH ESCUTCHEON

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08



DRY RECESSED SPRINKLER



DRY PENDANT SPRINKLER WITH SLEEVE AND SKIRT

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

ORDERING INFORMATION

P/N	GAXXXX Y Z LV

DESCRIPTION	CODE
Upright	GA5683
Pendent	GA5679

Y	1	57ºC	135ºF
	2	68ºC	155ºF
	4	79ºC	175ºF
	5	93ºC	200ºF
	7	141ºC	286ºF

Z	1	BRASS
	2	CHROME
	3	WHITE RAL9003

LV	02	2” – 5 ¾”	27	27” – 29 ¾”
	06	6” – 7 ¾”	30	30” – 32 ¾”
	08	8” – 11 ¾”	33	33” – 35 ¾”
	12	12” – 14 ¾”	36	36” – 38 ¾”
	15	15” – 17 ¾”	39	39” – 41 ¾”
	18	18” – 20 ¾”	42	42” – 44 ¾”
	21	21” – 23 ¾”	45	45” – 48”
	24	24” – 26 ¾”		

Specify:

Quantity	
Model Number	
Type	
Orifice	
Type deflector	
Temperature	
Finishes	
Escutcheon finish	

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08

AG FIRE SPRINKLER

AG Fire Sprinkler offers a wide selection of components. Then a list of products is presented by AG Fire Sprinkler, we can offer all these components, made with precision to protect people, anywhere, anytime.

- Sprinklers
  - Standard Coverage
  - Extended Coverage
  - Storage
  - Dry
  - Accessories
- System Valves
  - Wet
  - Dry
  - Preaction Equipment
  - Accessories
- Spray System Open Nozzles
  - High Velocity Nozzles
  - Medium Velocity Nozzles
  - Window Nozzles
  - Hydroshield Nozzles
  - Mushroom Type Nozzles
- Foam equipment
  - Tanks
  - Proportioners
  - Foam Discharge Equipment
  - Foam Concentrates
- Deluge equipment for Water Spray and Foam
  - Clapper Deluge Valves
  - Diaphragm Deluge Valves
- Monitors
  - Manual Monitors
  - Remote Monitors
  - Monitor Nozzles
  - Towers and Trolleys
- Valves
  - Butterfly Valves
  - Gate Valves
  - Check Valves
  - Pressure Control Valves
  - Test and Drain
  - Hose, Hydrant and Fire Connection Valves
  - Fire Department Connections

The equipment presented in this bulletin is to be installed in accordance with the latest published Standard of the National Fire Protection Association, Factory Mutual Research Corporation, or other similar organizations and also with the provisions of governmental codes or ordinances whenever applicable.
This documentation is not contractual. AG Fire Sprinkler reserves the right to any kind of change without notice.

C/Alfoz de Bricia nº4 | P.I. Villalonquéjar | 09001 Burgos (Spain) | Tlfno: +34 947 28 11 08